WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103700
Permit No.
Basin 137B

NOTICE OF INTENT NO. 59416

1. OWNER Milt & Judy Lott
MAILING ADDRESS

ADDRESS AT WELL LOCATION 98 & 99 Gillman Circle, Gillman Springs NV

2. LOCATION SE ~~SW~~ NW ~~#137B~~ ~~NE~~ Sec. 10 T. 16 N/S R. 44 E. Lander Co County
PERMIT NO. Waiver DOM07-011 (Issued by Water Resources) 004-033-20 (Parcel No.) Smokey Valley (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☒ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil	0	0	8'	8'
Cobbles + Gravel		8	35'	27'
Orange Clay + Gravel		35	50	15'
Soft Clay		50	54	4'
Gravel		54	85	31'
Clay & Gravel		85	130	45
Tan Clay		130'	160	30'
Gravel		160	185	25'
Clay		175'	185'	10'
Gravel Sand,				
And clay layers		175'	215	30'
Gravel + Clay		215	240	25'
GPS:				
N 39° 15.932'				
W 117° 01.300'				

Date started 4/25/07, 20
Date complated 4/26/07, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50-60	6pm	Air Lift	
3 Hrs.			
		N 39.265615	
		W 117.020742	NAD27

STATE ENGINEERS OFFICE
2007 MAY 11 AM 10:49
RECEIVED

8. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 241 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 240' Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.13 lbs	.188	+1	20'
6 5/8	pvc	SDR 21	20	240'

Perforations:
Type perforation Sawed
Size perforation 1/8 x 3"
From feet to feet
From 200' feet to 240' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100' feet to 240' feet

9. WATER LEVEL
Static water level 30' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Gillman Springs NV, 89429
Nevada contractor's license number issued by the State Contractor's Board 31841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740
Signed [signature] By driller performing actual drilling on site or contractor
Date 4/29/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627