STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103701
Permit No.
Basin 042

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59467

1. OWNER Bill Rodriguez
MAILING ADDRESS P.O. Box 626
Wells, NV 89835

ADDRESS AT WELL LOCATION 2 miles South of Wells HWY 93
Subdivision Name: County: Elko

2. LOCATION SW ¼ SW ¼ Sec 34 T 37N N/S R 62 E
PERMIT/WAIVER No. 73100 Issued by Water Resources Parcel No.

Latitude 41.0399N
Longitude 114.96022W
UTM E N AD 83
☐ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
LOAM		0	1	1
CEMENTED /GRAVEL		1	84	83
BROWN CLAY		84	141	57
FRACTURED ROCK	X	141	157	116
BROWN CLAY		157	162	5
HARD ROCK		162	172	10
BLUE CLAY		172	235	63

N 41.039990
W 114.959331 NAD27

Date started: 21-May, 20 07
Date completed: 5-Jun, 20 07

9. WELL CONSTRUCTION
Depth Drilled 235 Feet Depth Cased 235 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	235	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	15
6	SDR-17	PVC-SDR-17	15	235

Perforations:
Type of perforation SCREEN
Size of perforation 0.032
From 215 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 15 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 52 to 235 ☐ Pumped ☒ Poured
Type: 3/8 PEA GRAVE;
Bentonite Chips: ☐ Yes ☐ No 15 to 52 ☐ Pumped ☐ Poured
Type: 3/8 Kiwk plug

7. Water Level
Static water level: 127 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	.75		28

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SHAREL C. FERTIG SR. dba FERTIG DRILLING COMPANY (Contractor)
Address P.O. BOX 525 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on site or contractor)
Date 6-18-07

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY