

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

office use only
Log No. 103735
Permit No. _____
Basin. 082

NOTICE OF INTENT NO 59007

1. OWNER **Scott Simon**
MAILING ADDRESS **752 Zolezzi**
Reno, NV 89511

ADDRESS AT WELL LOCATION **752 Zolezzi**
Latitude N 39 deg 25.021 WGS 84
Longitude W 119 deg 45.912

2. Location NE 1/4 NW 1/4 20 Sec T18 N R20 E **Washoe** County
PERMIT NO. _____ PARCEL NO. **049-351-13** SUBDIVISION NAME _____

3. WORK PERFORMED			4. PROPOSED USE			5. WELL TYPE		
New Well	Replace	Recondition	<input checked="" type="checkbox"/> Domestic	Irrigation	Test	Cable	Rotary	RVC
Deepen	<input checked="" type="checkbox"/> Abandon	Other	Municipal/Industrial	Monitor	Stock	Air	Other	Mud

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
Bailed & perfed to 239'		0		0
Installed tremie to 239' & pumped neat cement to surface. We did get returns.				0

8. WELL CONSTRUCTION				
Depth Drilled	239 feet	Depth Cased	239 feet	
HOLE DIAMETER (BIT SIZE)				
	From	To		
	0	feet	feet	
	0	feet	feet	
	0	feet	feet	
CASING SCHEDULE				
0	Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet) To (Feet)
0	6 5/8	12.94	188	+1 1/2 239
Perforations:				
0	Type Perforation	Mills Knife		
0	Size perforation	1/4 x 3		
0	From	40 feet to	239 feet	
0	From	feet to	feet	
0	From	feet to	feet	
0	From	feet to	feet	
0	From	feet to	feet	
0	From	feet to	feet	
0	Surface Seal	<input checked="" type="checkbox"/> YES	No	Seal Type:
0	Depth of Seal	239 feet		<input checked="" type="checkbox"/> Neat Cement
0		<input checked="" type="checkbox"/> Pumped		Cement Grout
0		Poured		Concrete Grout
0	Gravel Packed:	Yes	No	
0	From	feet to	feet	

RECEIVED
2007 APR 26 AM 11:35
STATE ENGINEERS OFFICE

N 39.417124
W 119.764197 NAD27

Date started **3-28 -07**
Date completed **3-29 -07**

7. WELL TEST DATA			
TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)	

9. WATER LEVEL			
Static water level	96 feet below land surface		
Artesian flow	0 GPM	0 P.S.I.	
Water Temperature	cold Degrees F		Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**
2290 Pioneer Drive
Reno, NV 89509

NV Contractors No. **14170**
NV Driller's Lic (on site) **2121**

Signed *Steve McKay*
By driller performing actual drilling on site of contractor

Date **4-16 -07**