

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58029

1. OWNER Manuel Rodriguez ADDRESS AT WELL LOCATION unk
 MAILING ADDRESS unk 2102 Alabama Dr

2. LOCATION SE 1/4 SW 1/4 Sec 12 T 34 N 1/4 R 55 E Elko County _____
 PERMIT NO. N/A Issued by Water Resources 032-001-040 Parcel No. _____
Last Chance Ranch, Unit #3 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sandy loam</u>		<u>0</u>	<u>3</u>	<u>3</u>
<u>Sandy clay & gravel</u>		<u>3</u>	<u>7</u>	<u>4</u>
<u>Clay</u>		<u>7</u>	<u>51</u>	<u>44</u>
<u>Sandy clay</u>	<u>lgpm</u>	<u>51</u>	<u>54</u>	<u>3</u>
<u>Clay</u>		<u>54</u>	<u>191</u>	<u>137</u>
<u>Gravel & clay</u>	<u>100</u>	<u>191</u>	<u>218</u>	<u>27</u>
<u>Clay</u>		<u>218</u>	<u>220</u>	<u>2</u>
	<u>T. D.</u>	<u>220</u>		
<u>G.P.S. NO. 92012 N</u>				
<u>113-730920</u>				
<u>Flow: 5112 NAD27</u>				

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 221 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10+ Inches 0 Feet 50 Feet
8 Inches 50 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>±1</u>	<u>220</u>

Perforations:
 Type perforation torch cut
 Size perforation 1/2 x 1" x 2/16"
 From _____ feet to _____ feet
 From 190 feet to 215 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to T.D. feet

9. WATER LEVEL
 Static water level 51 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Muth Drilling Co. Contractor
 Address 203 Pine St. Elko, NV 89801 Contractor
 Nevada contractor's license number 10819 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James V. Muth By driller performing actual drilling on site or contractor
 Date 4-16-07

Date started 4-10-07
 Date completed 4-13-07

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>16</u>	<u>1 1/2</u>

RECEIVED
 2007 APR 25 AM 10:49