

Log No. 103749  
 Permit No. \_\_\_\_\_  
 Basin. 201

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59047

1. OWNER Lee Pearson ADDRESS AT WELL LOCATION 21 miles north of Spring Valley State Park in Camp Valley  
 MAILING ADDRESS HC 74 Box 260 Poche NV 89043  
 2. LOCATION NW N/E 1/4 Sec 10 T 4 S R 69 E Lincoln County  
 PERMIT NO. 69849 Issued by Water Resources Parcel No. 5-21-10 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Boulders - Sand		0	80	80
Clay - boulders		80	220	140
Boulders		220	260	40
Hard Rock		260	265	5

This was a dry hole, customer plans to deepen well in future. I have a mud Rotary Rig, penetration rate is terrible in bedrock, so customer is going to bring in a air rig with down hole hammer to deepen well

N 38.228761  
 W 114.234533 N4027

Datum WGS 84  
 N 38° 13.723'  
 W 114° 14.122'

8. WELL CONSTRUCTION

Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
11	0	265

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	0	265

Perforations:  
 Type perforation factory  
 Size perforation 1/2" V 5"  
 From 145 feet to 165 feet  
 From 185 feet to 265 feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 100  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 100' feet to 265 feet

9. WATER LEVEL  
 Static water level none - dry feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 8-10-07, 20 \_\_\_\_  
 Date completed 8-15-07, 20 \_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.R.M.	Draw Down (feet Below Static)	Time (Hours)
0		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Davis Drilling and Pumps Contractor  
 Address HC 61 Box 54 Hiko NV 89017 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0028966  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191  
 Signed Mike Davis  
 By driller performing actual drilling on site or contractor  
 Date 8-20-07