

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 103757  
 Permit No. \_\_\_\_\_  
 Basin. 101

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57497

1. OWNER Great Basin College Foundation ADDRESS AT WELL LOCATION 275 West Williams Ave - Fallon NV  
 MAILING ADDRESS P.O. Box 2056 Elko NV 89801

2. LOCATION N 1/4 NW 1/4 Sec 36 T 19 R 28 E Churchill County  
 PERMIT NO. NDEP # 5-060024 001-532-07 Parcel No. \_\_\_\_\_ Subdivision Name N/A  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG MW 7

Material	Water Strata	From	To	Thickness
<u>A/C</u>		<u>0</u>	<u>0.25</u>	<u>0.25</u>
<u>brown clayey sand</u>		<u>0.25</u>	<u>2</u>	<u>1.75</u>
<u>brown sandy clay</u>		<u>2</u>	<u>7</u>	<u>5</u>
<u>brown poor sand</u>	<u>8'</u>	<u>7</u>	<u>19</u>	<u>12</u>
<u>GPS</u>				
<u>N 39° 28.483'</u>				
<u>W 118° 46.784'</u>				
<u>N 39.474816</u>				
<u>W 118.778757 NAD27</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 19 Feet Depth Cased 19 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
8.5 Inches 0 Feet 19 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2" PVC</u>		<u>sch 40</u>	<u>0</u>	<u>19</u>

Perforations:  
 Type perforation slotted screened  
 Size perforation 0.010 inch  
 From 4 feet to 19 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-2' (bentonite 1-2')  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 2 feet to 19 feet

9. WATER LEVEL  
 Static water level 8' feet below land surface  
 Artesian flow NO G.P.M. N/A P.S.I.  
 Water temperature WATM °F Quality MURKY

Date started 1-31-07  
 Date completed 1-31-07

7. N/A WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DALE A. LEHMAN Contractor  
 Address 520 Edison Way Reno NV 89502 Contractor  
 Nevada contractor's license number C.E. 4186 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1976  
 Signed Dale A. Lehman  
 By driller performing actual drilling on site or contractor  
 Date 2-1-07