



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56722

1. OWNER Reynan & Bardis Development, LLC
 MAILING ADDRESS 1380 Greg St., Suite 230
Sparks, NV 89431

ADDRESS AT WELL LOCATION Between Miller Lane and Stock Lane in Fernley, NV. (Jackson Ranch)

2. LOCATION SW 1/4 NW 1/4 Sec. 14 T 20N
 PERMIT NO. n/a Issued by Water Resources
21-041-03 Parcel No.

N/S R 24E E Lyon County
 Subdivision Name n/a

3. WORK PERFORMED
 New Well
 Replace
 Recondition
 Deepen
 Abandon
 Other

4. PROPOSED USE
 Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE
 Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
There was a 4" monitor well and 2, 2" monitor wells at this location. We measured the 4" monitor well at 130' deep and the static water level was 41'. We installed 126' of tremmie pipe, mixed 18 bags of cement with approx. 100 gallons of water and pumped in from the bottom of the well to the surface. We then cut the 6" protective cover and the 4" casing to ground level. The 2" pvc monitor located 10' due east of the 4" well measured 46' deep with no water in the well. We pumped in neat cement from the surface until the well was full. There was also another 2" pvc monitor well located 10' due east of the other 2" monitor well. It measured 70' deep with a static water level of 56'. We installed 65' of 3/4" tremmie pipe and mixed 3 bags of cement with approx. 15 gallons of water and pumped the well full from bottom to the surface. Both protective covers were cut off the 2" monitor wells and the 2" pvc casing were cut off at ground level. An original well log for the 4" well is attached. GPS for all 3 wells is 39° 36.203W and 119° 15.96W, 4147' elevation Plugging of Log # 73240 N 39.603489 W 119.265008 NAD27 (these words put in since sec 15)				

8. WELL CONSTRUCTION

Depth Drilled 130' Feet Depth Cased 130' Feet
 HOLE DIAMETER (BIT SIZE)
 From To Feet
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		Sch. 40	+1	130'
2"		Sch. 40	+1	46'
2"		sch. 40	+1	70'

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 130', 46' & 70'
 Placement Method: Pumped
 Poured
 Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 4"-41' and 2"-56' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Carson Pump Contractor
 Address P.O. Box 20159 Contractor
Carson City, NV. 89721
 Nevada contractor's license number issued by the State Contractor's Board 39920
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 1/13/2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			