WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103793
Permit No.
Basin 093

NOTICE OF INTENT NO. 52993

1. OWNER Steve Barron
MAILING ADDRESS 7410 Matterhorn Blvd
Reno NV 89506
ADDRESS AT WELL LOCATION 7410 Matterhorn Blvd
Reno NV 89506

2. LOCATION NE ¼ NE ¼ Sec. 34 T. 22 N/S R. 19 E. Washoe County
PERMIT NO. Issued by Water Resources | 079-440-54 Parcel No. | Antelope Valley Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	55	55
Rock (Gray)		55	240	185
Rock (S.P.)		240	360	120
Rock (Frack)		360	500	140
N 39.73650				
W 119.82732	NAD27			

RECEIVED 2007 JAN -4 AM 11:07 STATE ENGINEER'S OFFICE

Date started 9/15, 2006
Date complated 12/4, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
60	400 pwl	16

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
18 Inches		0 Feet	17 Feet
11 Inches		17 Feet	240 Feet
8 3/4 Inches		240 Feet	500 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	3/16	0	500

Perforations:
Type perforation Saw slot
Size perforation 3/16
From 360 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 198 feet below land surface
Artesian flow No G.P.M. NA P.S.I.
Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenski Drilling & Pump Contractor
Address 15045 Red Rock Rd Contractor
Reno NV 89506
Nevada contractor's license number issued by the State Contractor's Board 50343
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed John F Olenski By driller performing actual drilling on site or contractor
Date 12/8/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627