

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52994

1. OWNER Damasio Martinez ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 75 Buckboard Cir. 75 Buckboard Cir.  
Reno NV 89506 Reno NV 89506  
 2. LOCATION NW 1/4 NW 1/4 Sec 11-T 23 OS R 18 E Washoe County  
 PERMIT NO. NE 078-191-03 Rancho Sierra Subdivision Name  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Misc

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	13	13
Clay		13	15	2
Sand		15	78	63
Clay		78	120	42
Sand		120	220	100

N 39. 87883°  
 W 119. 93153° NAD27

RECEIVED  
 2007 JAN -4 AM 11:07  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
13 Inches 0 Feet 15 Feet  
11 Inches 15 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.9</u>	<u>3/16</u>	<u>0</u>	<u>220</u>

Perforations:  
 Type perforation 3/16 Saw slot  
 Size perforation \_\_\_\_\_  
 From 180 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 220 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow Yes G.P.M. 3 P.S.I.  
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Olenki Drilling & Pump Co Contractor  
 Address 15045 Red Rock Rd. Contractor  
Reno NV 89506  
 Nevada contractor's license number 50343  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656  
 Signed John F. Olenki  
 By driller performing actual drilling on site or contractor  
 Date 1/2/07

7. WELL TEST DATA

Date started 12/13, 2007  
 Date completed 12/22, 2007

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>220</u>	<u>8</u>