

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29272

1. OWNER DEI ADDRESS AT WELL LOCATION Spring Valley 184  
 MAILING ADDRESS 755 Plamingo rd Las Vegas, NV 89119

2. LOCATION N 75° 15' W 1/4 SW 1/4 Sec. 18 T. 17 N. R. 68 E. White Pine County  
 PERMIT NO. M/O 1445 Issued by Water Resources Parcel No. Spring Valley 184 Subdivision Name 39° 20.50N 114° 22.26W 5539' W 6584'

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other auger

6. LITHOLOGIC LOG SVT

Material	Water Strata	From	To	Thick-ness
<u>silty sand</u>		<u>0</u>	<u>5</u>	
<u>br. silt</u>		<u>5</u>	<u>13</u>	
<u>sandy silt</u>	<u>20</u>	<u>13</u>	<u>33</u>	
<u>N 39.347285</u>				
<u>W 114.373038 NAD27</u>				

8. WELL CONSTRUCTION  
 Depth Drilled 33 Feet Depth Cased 33 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 0 Feet 33 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 in.</u>		<u>sch 40</u>	<u>0</u>	<u>33</u>

Perforations:  
 Type perforation Fac.  
 Size perforation .020  
 From 18 feet to 33 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 10  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 10 feet to 33 feet

9. WATER LEVEL  
 Static water level 20 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature cold °F Quality N/A

Date started 5/11 2007  
 Date completed 5/11 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>N/A</u>	<u>57:01 W</u>	<u>S-NAC 100Z</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Andresen Drilling  
 Address 11635 Bel Ford rd. Reno, NV 89509  
 Nevada contractor's license number 34525  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature]  
 Date 5/31/07  
 By driller performing actual drilling on site or contractor