WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA 19
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103889
Permit No.
Basin 212

→ City of Henderson 240 Water Street P.O. Box 95050 Henderson, NV 89009

NOTICE OF INTENT NO. 60275

1. OWNER Basic Remediation Company
MAILING ADDRESS 875 W. Warm Spring Rd
Henderson, NV 89011

ADDRESS AT WELL LOCATION Approx 1.0 miles NE of the intersection of Pabco Rd. & W Gallecia Dr.

2. LOCATION SW ¼ NE ¼ Sec. 31 T. 21 N/S 63 E Clark County

PERMIT NO. Issued by Water Resources | 160313010 03 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Sand with Gravel		0'	25'	25'
Clayey Sand	✓	25'	30'	5'
Muddy Creek Formation		30'	40'	10'
Silty ~~Sand~~ Clay				

NAD 83
680978 E 3994724 N

Date started 7-31-, 2007
Date completed 7-31-, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40' Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8" Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2 lbs/ft	Sch 40 0.474"	+3	15

Perforations:
Type perforation Sch 40 Factory Cut
Size perforation .020
From 15 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 13
Placement Method: ☐ Pumped ☑ Poured
Seal Type 3/8" Chips
☐ Neat Cement 13'-2'
☐ Cement Grout
☑ Concrete Grout 2'-0'

Gravel Packed: ☑ Yes ☐ No
From 13 feet to 40 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear Co. Contractor
Address 7773 W. Seldon Lane Peoria, AZ Contractor
85345
Nevada contractor's license number issued by the State Contractor's Board 0010157
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2148
Signed Phillip E. Cam
By driller performing actual drilling on site or contractor
Date August 17, 2007

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627