



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30993

1. OWNER City of Las Vegas ADDRESS AT WELL LOCATION
 MAILING ADDRESS 400 Stewart Ave Tule Springs Rd, Floyd Lamb Park
Las Vegas, NV 89101-0929 Las Vegas, Nevada
 2. LOCATION NW 1/4 SW 1/4 Sec. 24 T. 19 N. R. 60 E. Clark County
 PERMIT NO. 46352 125-04-301-005 Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Recreation Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Refer well log # 12029.				
Original well OD 14" to 142' ft				
then reduced OD 8" from				
142' ft to 688 ft				
Installed 10" Liner from 0 ft				
to 152 ft, with 132 feet of				
Screen.				
10" Liner sitting on top of				
8" well casing at 152 feet.				
Well cased to 698 feet.				
Videoed well to confirm				
casing together at 152 feet.				
Installed new 60 HP pump				
and motor into well.				
Lot 36° 19' 04" N NAD 83				
Long 115° 16' 10" W				

8. WELL CONSTRUCTION
 Depth Drilled 855 Feet Depth Cased 698 Feet
 HOLE DIAMETER (BIT SIZE)
 From To Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14			0	142'
10		.250	0	152'
8			152	698'

 Perforations: Factory Std Roll
 Type perforation Std Slot Perf.
 Size perforation 3 inch
 From 0 feet to 132 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal _____ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 112 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 8/8 2007
 Date completed 9/10 2007

7. WELL TEST DATA

TEST METHOD:		Time (Hours)	
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	Time (Hours)

DCN
 RECEIVED
 OCT 08 2007
 LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name TDC Drilling Contractor
 Address 2870 W. Pebble Rd Contractor
Las Vegas, NV 89123
 Nevada contractor's license number 59948
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2316
 Division of Water Resources, the on-site driller
 Signed R-R [Signature]
 By driller performing actual drilling on site or contractor
 Date 9-10-07