WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
003723

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

3 WELLS

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103941
Permit No.
Basin 212

NOTICE OF INTENT NO. 31485

1. OWNER BIG DADDY'S OIL LLC
MAILING ADDRESS P.O. Box 30547
LAS VEGAS NV

ADDRESS AT WELL LOCATION 4380 SPRING MOUNTAIN RD.
LAS VEGAS NV

2. LOCATION NW ¼ NE ¼ Sec. 18 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. (Issued by Water Resources) | Parcel No. 162-18-504-001 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0.0	0.4	0.4
SAND & GRAVEL		0.4	3.0	2.6
CONCRETE SAND W/GRAVEL		3.0	6.0	3.0
CLAY		6.0	11.0	5.0
SILTY CLAY		11.0	22.0	11.0
WEAK CACIUM		22.0	23.0	1.0
SILTY CLAY		23.0	25.0	2.0
CLAY W/GRAVEL		25.0	30.0	5.0

MAP DATUM WGS84
mw-1 36°07.594 N 115°11.940 W
mw-2 36°07.593 N 115°11.915 W
mw-3 36°07.597 N 115°11.917 W

NOEP #
8-000024

Date started 10/08, 2007
Date completed 10/09, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR
RECEIVED
OCT 16 2007
LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11½ Inches		0 Feet	30 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.25		SCH40 PVC	30	0

Perforations:
Type perforation MACHINE SLOT
Size perforation .020
From 30 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 13'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 30 feet to 13 feet

9. WATER LEVEL
Static water level 21 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILLING SERVICES LLC (Contractor)
Address 7150 PLACID ST (Contractor)
LAS VEGAS NV 89119
Nevada contractor's license number issued by the State Contractor's Board 57266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
Signed (By driller performing actual drilling on site or contractor)
Date 10/12/07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627