



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30994

1. OWNER Davis Brothers investment ADDRESS AT WELL LOCATION 14330 Garza St  
 MAILING ADDRESS 7210 Placid Sloah NV 89124  
Las Vegas NV 89119  
 2. LOCATION NE 1/4 SW 1/4 Sec. 19 T. 23 N. R. 61 E. Clark County  
 PERMIT NO. 73348 Issued by Water Resources Parcel No. 191-19-301-005 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Commercial  Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel & Sand		945	1160	215
Gray Clay		1160	1163	3
Gravel & Sand		1163	1230	67
Gray Clay		1230	1234	4
Sand & Gravel		1234	1260	26
Refer to original well log # 37743				
Original well cased in 6" steel from 0' to 945'				
Deepened well to 1260' and installed 4 1/2" PVC casing from 924' to 1260'				
DONOR/DWR RECEIVED				
OCT 22 2007				
LAS VEGAS OFFICE				
Waiver R-1385				
GPS 35° 55' 53" N 115° 12' 09" W NAD 83				

8. WELL CONSTRUCTION  
 Depth Drilled 1260 Feet Depth Cased 1260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 5 7/8 Inches 945 Feet To 1260 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>		<u>Factory</u>	<u>945</u>	<u>1260</u>

Perforations:  
 Type perforation Factory PVC  
 Size perforation  
 From 924 feet to 1260 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 753 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 60.1 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name TDC Well Drilling Contractor  
 Address 2870 W. Pebble Rd. Contractor  
Las Vegas NV 89123  
 Nevada contractor's license number issued by the State Contractor's Board 59948  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2316  
 Signed R. R. Brown  
 By driller performing actual drilling on site or contractor  
 Date 10-22-07

Date started 10-06 2007  
 Date completed 10-17 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		<u>1 1/2</u>