WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103972
Permit No. 29059
Basin 212

NOTICE OF INTENT NO. 30530

1. OWNER Las Vegas Valley Water District
MAILING ADDRESS 1001 S. Valley View Blvd.
Las Vegas, NV 89153
ADDRESS AT WELL LOCATION 1201 N. Rainbow
Las Vegas, NV

2. LOCATION NE ¼ NE ¼ Sec. 27 T. 20 N/S R. 60 E. CLARK County
PERMIT NO. R-003 29059 Issued by Water Resources 138-27, 502-004 Part NONE Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BRUSH WELL From 455'-668'				
Bail Fill From Well 906'-923'				
UTM E 658024.75				
UTM N 4005916	NAD 83	Format		

UCNR/DWR RECEIVED OCT 25 2007 LAS VEGAS OFFICE

Date started 10-1, 2007
Date completed 10-5, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 1000 Feet Depth Cased 997 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
24	Inches	0	Feet	51	Feet
20	Inches	51	Feet	1000	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
24		5/16	0	51
20		6+8 gau.	0	700
14		5/16	673	997

Perforations:
Type perforation Moss Hydraulic
Size perforation 5/16" x 1 1/2"
From 455 feet to 668 feet
From feet to feet
~~From~~ Shutter Screen ~~feet to~~ 3/16 Full Flow ~~feet~~
From feet to feet
From 697 feet to 985 feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 51'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 673 feet to 1000 feet

9. WATER LEVEL
Static water level 308 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name
Contractor
Address
Contractor

Nevada contractor's license number issued by the State Contractor's Board NONE
Nevada driller's license number issued by the Division of Water Resources, the on-site driller PMPLTD-2171
Signed Jason Shaw
By driller performing actual drilling on site or contractor
Date 10-25-07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627