

COPIES TO

- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

STATE OF NEVADA

DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 103977

Permit No. \_\_\_\_\_

Basin 105

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **58252**

1. OWNER **TONY MOORE**  
MAILING ADDRESS **4861 SAVORY BLVD PAHRUMP, NV 89061**

ADDRESS AT WELL LOCATION **1980 CHUKAR LN GARDNERVILLE, NV 89410**

2. LOCATION **SE 1/4 SE 1/4 Sec 13 T 12 N R 20 E DOUGLAS County**

PERMIT NO. **1220-13-801-042**  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **MUD**

6. LITHOLOGIC LOG

| Material                          | Water Strata | From | To  | Thickness |
|-----------------------------------|--------------|------|-----|-----------|
| OLD 8 5/8 WELL                    |              | +2   | 160 | 160       |
| BROWN CLAY                        |              | 160  | 218 | 78        |
| SMALL OBSIDIAN SANDS              |              | 218  | 243 | 25        |
| BROWN CLAY                        |              | 243  | 260 | 17        |
| SMALL GRAVELS FRACTURED ROCK      | XXX          | 260  | 320 | 60        |
| N 38.847408<br>W 119.677957 NAD27 |              |      |     |           |

8. WELL CONSTRUCTION

Depth Drilled 320 -160 Feet Depth Cased 320 -170 Feet  
HOLE DIAMETER (BIT SIZE)  
From 7 7/8 Inches To 160 Feet 320 Feet  
Inches Feet Feet  
Inches Feet Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
6 5/8 13.03 .188 150 320

Perforations:  
Type perforation **FACTORY MILL SLOT**  
Size perforation **3 X 3/32**  
From 260 feet to 280 feet  
From 300 feet to 320 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal N/A  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From N/A feet to N/A feet

GPS INFO: NAD 83  
38.89731\*N  
119.67845\*W

9. WATER LEVEL  
Static water level 125 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M \_\_\_\_\_ P.S.I  
Water temperature COLD °F Quality GOOD

7. WELL TEST DATE

| TEST METHOD:                  | <input type="checkbox"/> Bailer | <input type="checkbox"/> Pump | <input checked="" type="checkbox"/> Air Lift |
|-------------------------------|---------------------------------|-------------------------------|--|
| Draw Down (Feet Below Static) | <u>65</u>                       |                               |  |
| G.P.M.                        | <u>25</u>                       |                               |  |
| Time (Hours)                  | <u>3 HRS</u>                    |                               |  |
| 2007 MAY -7 PM 1:03           |                                 |                               |  |
| RECEIVED                      |                                 |                               |  |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name **CAPITAL CITY WELL DRILLING** (CONTRACTOR)  
Address **20 KIT KAT DRIVE** (CONTRACTOR)  
**CARSON CITY, NV 89706**  
Nevada contractor's license number issued by the State Contractor's Board **0055548**  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1905**  
Signed Michael H. Beck  
By driller performing actual drilling on site or contractor  
Date 4/28/07