COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 103979
Permit No.
Basin 105

NOTICE OF INTENT NO. 58253

1. OWNER PAT & MELT SIMMONS
MAILING ADDRESS 774 PINTO CIR
GARDNERVILLE, NV 89410

ADDRESS AT WELL LOCATION 774 PINTO CIR
GARDNERVILLE, NV 89410

2. LOCATION ~~NW~~ ¼ NW ¼ Sec 24 T 12 N R 20 E DOUGLAS County

PERMIT NO. NE (Issued by Water Resources) | 1220-24-101-008 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 6 5/8 WELL		+2	120	120
COURSE GRAVELS		120	138	18
BROWN CLAY		138	169	31
BROWN SILTY SANDS		189	195	6
COURSE GRAVELS	XXX	195	220	25

N 38.89445/8
W 119.68816 NAD27

GPS INFO: NAD 83
38.89442*N
119.68916*W

Date started 4/17, 20 07
Date completed 4/19, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	45	3 HRS

2007 MAY 15 AM 10:46

8. WELL CONSTRUCTION

Depth Drilled 220 ~~100'~~ Feet Depth Cased 220 ~~120~~ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 1/8 Inches	120 Feet	220 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	11.94	.188	100	220

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 180 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal N/A ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 5/8/07