

STATE OF NEVADA
DIVISION OF WATER RESOURCES



OFFICE USE ONLY

Log No. 104139
Permit No. _____
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60803

1. OWNER Dave Gieratz
MAILING ADDRESS 1951 Hillsboro Blvd Fallon, NV 89406
Fallon, NV 89406

ADDRESS AT WELL LOCATION 6290 Westwind
Fallon, NV 89406

2. LOCATION NW 1/4 SE 1/4 Sec 19 T 19 R 28
PERMIT NO Parcel No. 008-152-35

Latitude 39.49542 Longitude -118.88126 WGS 84
Subdivision Name _____ County Churchill

3. WORK PERFORMED
New Well - Replacement *of log # 28925*

4. PROPOSED USE
Domestic

5. WELL TYPE
Rotary-mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	23	23
Brown Clay		23	26	3
Brown Sand		26	46	20
Brown Clay		46	54	8
Brown Sand	X	54	60	6

*N 39.495521
W 118.880280 NAD27*

8. WELL CONSTRUCTION

Depth Drilled 60 Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

From	To
12.3 Inches	0 Feet 50 Feet
10 Inches	50 Feet 60 Feet
Inches	Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
6.625	12.92	0.188	0	17
6	4.0	0.316	17	60

Perforations:

Type perforation Saw Cut
Size perforation 0.125
From 57 feet to 60 feet

Surface Sea Yes No

Seal Type:
Concrete Grout

Depth of Seal 50

Placement Method: Pumped

Gravel Packed: Yes No

From 50 feet to 60 Feet

9. WATER LEVEL

Static Water Level 21 feet below land surfac

Artesian Flow G.P.M. P.S.I.

Water temperature ° F Qualit unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contracto

Address 403 McLean Road
Fallon, NV 89407

Contracto

Nevada contractor's license number 29064
issued by the State Contractor's

Nevada driller's license number issued by the 2307
Division of Water Resource, the on-site driller

Signe *[Signature]*

By driller performing the actual drilling on site or contract

Date 10/25/2007

Date started 10/17/2007

Date completed 10/17/2007

7. WELL TEST DATA

TEST METHOD Air

Comments	GPM	Drawdown	Time (Hours)
	10		1

STATE ENGINEERS OFFICE

2007 NOV 14 AM 11:14

RECEIVED