COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104152
Permit No.
Basin 105

NOTICE OF INTENT NO. 58264

1. OWNER ROGER ROGALSKI
MAILING ADDRESS 935 WINTER GREEN AVE
GARDNERVILLE, NV 89460

ADDRESS AT WELL LOCATION 2580 OLD RANCH RD
GARDNERVILLE, NV 89410

2. LOCATION ~~SE~~ NE ¼ ~~NE~~ SE ¼ Sec 9 T 12 N R 21 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | Parcel No. 1221-09-002-003 | Subdivision Name FISH SPRINGS

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	6	6
BROWN CLAY		6	12	6
SMALL GRAVELS		12	112	100
OBSIDIAN SANDS		112	210	98
BROWN CLAY		210	255	45
SMALL GRAVELS COLOR SANDS 10 GPM	XXX	255	280	25
GRAY CLAY		280	321	41
GRAY SILTY CLAY		321	342	21
DG SANDS GREEN SANDS	XX	342	400	58

N 38.916818
W 119.622848 NAD27

GPS INFO: NAD 83
38.91672 N
119.62389 W

Date started 5/28, 20 07
Date completed 6/3, 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
16	105	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 5/8 Inches	0 +2 Feet	280 Feet
6 1/8 Inches	280 Feet	400 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	280
5	11.63	.188	175	400

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 260 feet to 280 feet
From 360 feet to 400 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 280 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M 16 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael J Hack
By driller performing actual drilling on site or contractor
Date 6/25/07