COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104134
Permit No.
Basin 089

NOTICE OF INTENT NO. 58266

1. OWNER DENNIS HOF
MAILING ADDRESS 5605 MADRAS ST
WASHOE VALLEY , NV 89704

ADDRESS AT WELL LOCATION 5580 MARLOWE DR
WASHOE VALLEY , NV 89704

2. LOCATION ~~SW~~ NW ¼ SW ¼ Sec 14 T 16 N R 19 E WASHOE County

PERMIT NO. | Issued by Water Resources | 055-140-05 Parcel No. | WASHOE # WL070060 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL		+2	98	100
COURSE DG SANDS		98	135	37
BROWN CLAY		135	162	27
COURSE DG SANDS	XX	162	200	38

N 39.250955
W 119.832498 NAD27

GPS INFO: NAD 83
39.25085*N
119.82350*W

Date started 6/14 , 20 07
Date completed 6/15 , 20 07

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+	35	3 HRS

2007 JUL 11 AM 11:22

8. WELL CONSTRUCTION
Depth Drilled 200 ~~102'~~ Feet Depth Cased 200 ~~120~~ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 7/8 Inches	92 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	80	200

Perforations:
Type perforation FACTORY MILL SLOT
Size perforation 3 X 3/32
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No Seal Type:
Depth of Seal N/A ☐ Neat Cement
Placement Method: ☐ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From N/A feet to N/A feet

9. WATER LEVEL
Static water level 43' feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed
By driller performing actual drilling on site or contractor
Date 7/7/07