

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 104156
Permit No. _____
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59752

1. OWNE Wayne Sauer
MAILING ADDRESS 3280 York Lane Fallon, NV 89406
Fallon, NV 89406

ADDRESS AT WELL LOCATION 3280 York Lane
Fallon, NV 89406

2. LOCATION ~~SW~~ 1/4 ~~NE~~ 1/4 Sec 27 T 19 R 28
PERMIT NO NW NE Parcel No. 010-103-21

Latitude 39.48643 Longitude -118.82489 WGS 84
Subdivision Name _____ County Churchill

3. WORK PERFORMED
New Well - Replacement

4. PROPOSED USE
Domestic

5. WELL TYPE
Rotary-mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	43	43
Gray Clay		43	46	3
Gray Sand		46	68	22
Brown Clay		68	71	3
Brown Sand	X	71	80	9

N 39.486530
W 118.823912 NAD27

8. WELL CONSTRUCTION

Depth Drilled 80 Depth Cased 80 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	50 Feet
10 Inches	50 Feet	80 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O D (inches)	Weight/Ft. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
6.625	12.92	0.188	0	17
6	4.0	0.316	17	80

Perforations:

Type perforation Saw Cut
Size perforation 0.125
From 75 feet to 80 feet

Surface Seal Yes No

Seal Type:

Depth of Seal 50

Cement Grout

Placement Method: Pumped

Gravel Packed: Yes No

From 50 feet to 80 Feet

9. WATER LEVEL

Static Water Level 16 feet below land surfac

Artesian Flow G.P.M. P.S.I.

Water temperature ° F Qualit Unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contracto

Address 403 McLean Road

Fallon, NV 89407

Contracto

Nevada contractor's license number 29064

issued by the State Contractor's

Nevada driller's license number issued by the Division of Water Resource, the on-site driller 2307

Signe [Signature]

By driller performing the actual drilling on site or contract

Date 5/1/2007

Date started 4/23/2007

Date completed 4/23/2007

7. WELL TEST DATA

TEST METHOD Air

Comments	GPM	Drawdown	Time (Hours)
	10	1	

STATE ENGINEERS OFFICE

2007 MAY 22 AM 10:55

RECEIVED