

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 104226
 Permit No. _____
 Basin 105

NOTICE OF INTENT NO. 59730

1. OWNER Comstock Seed ADDRESS AT WELL LOCATION 917 Hwy 89
 MAILING ADDRESS _____
 2. LOCATION NW SE 1/4 12 T 12 N/S R 20 E Douglas County
 PERMIT NO. 20095 73809 1220-18-001-011 Issued by Water Resources Parcel No. _____
 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL-CLAY		0	3	3
SAND		3	8	5
GRAVEL-LARGE	X	8	68	60
MEDIUM SANDY GRAVEL	X	68	118	50
LARGE GRAVEL	X	118	187	69
38.90229°N				
119.77738°W NAD83				
RECEIVED 2007 SEP 14 AM 10:46 STATE ENGINEERS OFFICE				
N 38.902389				
W 119.776384 NAD83				

8. WELL CONSTRUCTION
 Depth Drilled 187 Feet Depth Cased 187 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 187 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 1/2</u>		<u>.188</u>	<u>71</u>	<u>187</u>

Perforations:
 Type perforation Factory milled
 Size perforation 3/32" x 3
 From _____ feet to _____ feet
 From 107 feet to 187 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 100 FT Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 187 feet

Date started 17 July, 2007
 Date completed 16 July, 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100 +</u>		<u>2.5</u>

9. WATER LEVEL
 Static water level 6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name _____ Contractor
BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255
Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Dotson
 By driller performing actual drilling on site or contractor
 Date 21 July 07