

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 58028

1. OWNER MARCOS RODRIQUEZ ADDRESS AT WELL LOCATION 2425 Owl Rd
 MAILING ADDRESS _____

2. LOCATION SW 1/4 SE 1/4 Sec. 12 T. 34 N. R. 55 E. ELKO County
 PERMIT NO. N/A Issued by Water Resources Parcel No. 032-001-045 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan Sandy clay		0	5	5
Gray/Green clay		5	123	118
Sandy clay & gravel	5' pipe	123	124	1
Sandy clay		124	284	100
Sandy clay	2.9 pm	284	285	1
Thin streaks of sandy clay & clay	8' pm	284	316	32
T.P. 326				
6. P.S. NA027				
40. 84000 N				
115. 72502 W				
Elev. 5135				

8. WELL CONSTRUCTION
 Depth Drilled 316 Feet Depth Cased 316 Feet

HOLE DIAMETER (BIT SIZE)
 From 10.1 Inches To 0 Feet 316 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" 5/8	13.92	.188	±1	316
5" 7/8 PVC screen		.25	308	316

Perforations:
 Type perforation Torch cut & screen
 Size perforation 1/8" x 4"
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 316 feet

9. WATER LEVEL
 Static water level 8.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name MUTH DRILLING Co. Contractor
 Address 203 Pine St. Elko, NV 89801 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 10019
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 632
 Signed James V. Muth
 By driller performing actual drilling on site or contractor
 Date 5-19-07

Date started 4-17-07, 19____
 Date completed 5-10-07, 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

Time (Hours)	Draw Down (Feet Below Static)
2007 OCT 11 AM 11:02	5
2007 OCT 11 AM 11:34	5.5

RECEIVED