STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104364
Permit No.
Basin 161

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34694

1. OWNER Rodney Dukes - TOUCAN TRUST
MAILING ADDRESS 200 Rainbow Canyon
Mt. Charleston, NV 89124
ADDRESS AT WELL LOCATION ~~Unincorp~~ Clark
Subdivision Name Country

2. LOCATION SE ¼ NE ¼ Sec. 36 T 17 N R 55 E
PERMIT/WAIVER No.
Latitude 36 25.776N
Longitude 115 44.543W
Parcel No. 092-36-601-016
☐ NAD 27 ■ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand & Gravel | | | | |
| Fractured Limestone | | 0 | 110 | 110 |
| Fractured Limestone | X | 110 | 140 | 30 |
| Clay & Sand Loam | | 140 | 155 | 15 |
| Gravels | X | 155 | 210 | 55 |

Date started: Oct 16, 20 07
Date completed: Oct 22, 20 07

9. WELL CONSTRUCTION
Depth Drilled 210 Feet Depth Cased 210 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 1/4 | Inches | 0 | Feet | 210 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 | F | 480 PVC | +1 | 210 |

Perforations
Type of perforation Saw Cut
Size of perforation 1/8 X 3
From 110 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☒ Yes ☐ No
☐ Neat Cement 0 to 100 ☐ Pumped ☒ Poured
☒ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level 101 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 100 | 125 | 30 min |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling & Pump Svc.
Contractor
Address 530 E. Larson Lane
Contractor
Henderson, NV 89044
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
Signed Ronald S Torsky
By driller performing actual drilling on site or contractor
Date 10-23-07

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-05)

CONR/DWR
OCT 24 2007
LAS VEGAS OFFICE