

Plugged by
NOI 65734

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104373
Permit No. _____
Basin 179
NOTICE OF INTENT NO. 61465

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Quadra-Robinson NV Mining PZ 07-06 ADDRESS AT WELL LOCATION Robinson Mine
MAILING ADDRESS P.O. Box 382 2 miles South of Ruth, Nevada
Ruth, Nevada Subdivision Name: N/A County: White Pine

2. LOCATION NE 1/4 SE 1/4 Sec 10 T16N R62E Latitude 674988 UTM E NAD 27
PERMIT/WAIVER NO. NEV0092105 N/A Longitude 4347715 N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Unconsolidated Rock		0'	115'	115'
No Sample-Void		115'	130'	15'
Grey Limestone		130'	145'	15'
No Sample-Void		145'	165'	20'
Gray Limestone		165'	205'	40'
White/Grey Limestone		205'	245'	40'
Gray Limestone		245'	255'	10'
White/Grey Limestone		255'	280'	25'
White/Brown Limestone		280'	450'	170'
White/Brown Sandstone		450'	485'	35'
Dark Grey Shale		485'	1045'	560'
Notes:				
Native Material		960'	1045'	85'
<u>N 39.263000</u>				
<u>W 114.971768 NAD27</u>				

9. WELL CONSTRUCTION

Depth Drilled 1045 Feet Depth Cased 960 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>12.75</u> Inches	<u>0</u> Feet to <u>40</u> Feet
<u>6.5</u> Inches	<u>40</u> Feet to <u>1045</u> Feet
_____ Inches	_____ Feet to _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8.625</u>	<u>22.36</u>	<u>.250</u>	<u>0</u>	<u>40</u>
<u>2.375</u>	<u>3.65</u>	<u>.154</u>	<u>+1</u>	<u>960</u>

Perforations:

Type of perforation Slotted

Size of perforation .030

From 900 feet to 960 feet

From _____ feet to _____ feet

Annular Seal: Yes No

Neat Cement 0 to 50 Pumped Poured

Cement Grout _____ to _____ Pumped Poured

Concrete Grout _____ to _____ Pumped Poured

≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 890' to 960' Pumped Poured

Type: _____

Bentonite Chips: Yes No 50' to 890' Pumped Poured

Type: 3/8 Hole Plug

7. Water Level

Static water level: 925 feet below land surface

Artesian Flow: _____ G.P.M. _____ P.S.I.

Water Temperature: _____ °F

Quality: _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Boart Longyear Drilling Services
(CONTRACTOR)

8. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
Draw Down			
G.P.M. @ _____ (Feet Below Static)	<u>N/A</u>	<u>N/A</u>	<u>2</u>
Time (Hours)			
<u>2007 OCT 22 PM 1:17</u>			
<u>ROBINSON</u>			

Address P.O. Box 5279
(CONTRACTOR)

Elko, Nevada 89802-5279

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 16-Oct-07

