REPORT NO. A07.91

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

I

LOG NO. 104374
PERMIT NO.
BASIN 038

NOTICE OF INTENT NO. 61141

1. OWNER Ryan & Jenny Ramsdell
MAILING ADDRESS 1225 Lander St, Reno NV 89509

ADDRESS OF WELL 19755 Paddlewheel Lane
Reno NV

2. WELL LOCATION SW 1/4 SE 1/4 SEC. 04 T 17 R 20 E Washoe COUNTY

PERMIT NO ____ PARCEL NO 017-371-03 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Brown Clay		0	10	10
Brown Clay & D.G		10	20	10
Brown Clay & Sand		20	30	10
Brown & Gray Clay		30	40	10
Gray Clay		40	60	20
Brown Clay & Gravel		60	70	10
Green & White Granite		70	80	10
Light Brown Clay		90	100	10
Lt Brown Clay & Multi Color Rock		100	120	20
Light Brown & Gray Clay		120	130	10
Brown Clay		130	140	10
Brown & Gray Clay		140	170	30
Light Tan Clay		170	190	20
Dark Brown Clay		190	200	10
Red Volcanic Rock & Red Clay		200	300	100

Notes : WGS-84 GPS: Latitude: N39 21.801 Longitude: W119 44.526

N39.363456
W119.741098 NAD27

Date Started 09/27/2007 Date Completed 10/10/2007

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	15+		3

8. WELL CONSTRUCTION
Depth Drilled ~~298'~~ 300 Depth Cased ~~298'~~ 300

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches 0 Feet 298 Feet
____ Inches ____ Feet ____ Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8"	12.92	.188	+2'	~~298~~ 300

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 3
From 120 Feet to 180 Feet
From ____ Feet to ____ Feet
From 280 Feet to 300 Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 100
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 100 Feet to 300 Feet

9. WATER LEVEL
Static Water Level 16 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Warm F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 1132T

Signed [signature]
By driller performing actual drilling on site or contractor

Dated Oct 18 2007

STATE ENGINEERS OFFICE
2007 OCT 22 PM 1:17
RECEIVED