STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104397
Permit No.
Basin 059

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 59829

1. OWNER Newmont Mining Corp.
MAILING ADDRESS PO Box 69
Golconda, NV 89414

ADDRESS AT WELL LOCATION Phoenix Mine
Hole #PHX-20073 Well #PHX-DD
Subdivision Name: County: Lander

2. LOCATION ~~SE~~ SW ¼ SW ¼ Sec 26 T 31N N/S R 43 E
PERMIT/WAIVER No. NEV87061 Issued by Water Resources Parcel No.

Latitude 40° 31' 28.186" N
Longitude 117° 06' 23.450" W
UTM E 1611076.669' [x] NAD 27
N 14717089.518' [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandstone		0	30	30
Shale		30	35	5
Sandstone		35	350	315
Encounter H2O 7.5 gpm				
270 to 280 Static @ 272'				
Trimmy in 31 50# sacks #8 sand				
up to 297'				
Pour in 2 cubic yars of 3/8"				
hole plug				
Pour in 150 gal neat cement				
slurry				
Develop well with air				
Develop up good				
Weld on monument and place				
cap on				
Pour cement monument pad				
N 40.524496				
W 117.106514 NAD27				

Date started: 24-Sep , 20 07
Date completed: 8-Oct , 20 07

9. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14 3/4	Inches	0	Feet	20	Feet
8 3/4	Inches	20	Feet	320	Feet
8 1/2	Inches	320	Feet	350	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		Sch 80	+3	-350

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 300 feet to 340 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 0 to 50 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 297 to 350 [x] Pumped [ ] Poured
Type: #8 Sand
Bentonite Chips: [x] Yes [ ] No 297 to 50 [ ] Pumped [x] Poured
Type: 3/8" Hole Plug

7. Water Level
Static water level: 272 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
7.5		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2089
Signed Donald Shoorl by [illegible] (By driller performing actual drilling on site or contractor)
Date 10/8/2007

RECEIVED 2007 OCT 18 AM 10:56 STATE ENGINEER'S OFFICE

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY