

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 104624  
Permit No. \_\_\_\_\_  
Basin 101

TT806-MW02

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54767

1. OWNER DEPT OF NAVY NAS FALLON ADDRESS AT WELL LOCATION 4755 Pastore Rd  
MAILING ADDRESS 4755 Pastore Rd Fallon, NV. 89496  
Subdivision Name: NAS FALLON County: Churchill

2. LOCATION SW 1/4 SW 1/4 Sec 22 T 18 N R 29 E Latitude \_\_\_\_\_ UTM E 1150351809  NAD 27  
PERMIT/WAIVER No. IRP Longitude \_\_\_\_\_ N 4363103  NAD 83/WGS 84  
Issued by Water Resources Parcel No. 006-611-01

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other Acq

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SILT</u>		<u>0'</u>	<u>3'</u>	<u>3'</u>
<u>CLAYEY SAND</u>		<u>3'</u>	<u>5'</u>	<u>2'</u>
<u>SILT</u>		<u>5'</u>	<u>9'</u>	<u>4'</u>
<u>SAND</u>		<u>9'</u>	<u>11'</u>	<u>2'</u>
<u>SILTY CLAY</u>		<u>11'</u>	<u>12'</u>	<u>1'</u>
<u>SAND</u>		<u>12'</u>	<u>18'</u>	<u>6'</u>

N 39.404813  
W 118.720199 NAD27

9. WELL CONSTRUCTION  
Depth Drilled 18' Feet Depth Cased 18' Feet  
HOLE DIAMETER (BIT SIZE)  
8" From 0' To 18' Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>		<u>SCH. 40</u>	<u>0'</u>	<u>18'</u>

Perforations:  
Type of perforation Manufactured slotted  
Size of perforation 1.010  
From 18' feet to 3' feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement 0' to 1'  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 18' to 2'  Pumped  Poured  
Type: 2/16 Sand

Bentonite Chips:  Yes  No 1 to 2  Pumped  Poured  
Type: 3/8 Bentonite chips

Date started: 10-14-07 :20 07  
Date completed: 10-14-07 :20 07

7. Water Level  
Static water level: 5' feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

STATE ENGINEERS OFFICE  
2007 OCT 30 PM 2:57  
RECEIVED

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Gregg Drilling Contractor  
Address 950 Howe Rd Contractor  
Martinez CA. 94553  
Nevada contractor's license number C23.0038113  
issued by the State Contractor's Board  
Nevada driller's license number issued by the M-2328  
Division of Water Resources, the on-site driller  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 10-14-07