STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 1024656
Permit No.
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60301

1., OWNER ANDREZEJ BUGAJSKI
MAILING ADDRESS 5757 ETHEL WY
CARSON CITY , NV 89701

ADDRESS AT WELL LOCATION 6275 ROBERT HILL RD
CARSON CITY , NV 89701
Subdivision Name: County: Carson City

2. LOCATION SE ¼ SW ¼ Sec 34 T 15N N/S R 19 E
PERMIT/WAIVER No. 007-051-23 Parcel No.
Issued by Water Resources

Latitude 39.11671°N
Longitude 119.83619°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD WELL 6 5/8		+2	240	240
COURSE DG SANDS	XXX	240	320	80
D				
N 39.116813				
W 119.835189 NAD27				

Date started: 15-Oct , 20 07
Date completed: 17-Oct , 20 07

9. WELL CONSTRUCTION
Depth Drilled 320 ~~80~~ Feet Depth Cased 320 ~~120~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	240	Feet	320	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	11.68	.188	200	320

Perforations:
Type of perforation factory mill slot
Size of perforation 3 x 3/32
From 300 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement n/a to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No n/a to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 150 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	80	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael J Stack
By driller performing actual drilling on site or contractor
Date 10/18/2007

(Rev. 05-09)

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED
2007 OCT 24 AM 11:08
STATE ENGINEER'S OFFICE