STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104652
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61001

1. OWNER DELORES SHEETS
MAILING ADDRESS 1411 NORD CT
GARDNERVILLE , NV 89460

ADDRESS AT WELL LOCATION 1411 NORD CT
GFARDNERVILLE , NV 89460
Subdivision Name: County: DOUGLAS

2. LOCATION SW ¼ SW ¼ Sec 10 T 12N N/S R 20 E
PERMIT/WAIVER No. 1220-10-401-009
Issued by Water Resources Parcel No.

Latitude 38.91298°N
Longitude 119.73184°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 6 5/8 WELL		0	120	120
COURSE GRAVELS		120	163	43
BROWN CLAY		163	191	28
GRAVELS	XXX	191	220	29
TD : 220				
N 38.913079				
W 119.730845 NAD27				

Date started: 01-Oct , 20 07
Date completed: 02-Oct , 20 07

7. *Water Level*
Static water level: 84' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20+	43	3 HRS

9. *WELL CONSTRUCTION*
Depth Drilled 220 ~~100'~~ Feet Depth Cased 220 ~~100'~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	120'	Feet	220'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"	11.62	.188	100'	220'

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3 X 3/32
From 200' feet to 220' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type: N/A
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type: N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY , NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed
By driller performing actual drilling on-site or contractor
Date 10/11/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED
2007 OCT 24 AM 11:09
STATE ENGINEER'S OFFICE