STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 1046716
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60513

1. OWNER CODY ALLEN
MAILING ADDRESS 336 OSINO UNIT 7
ELKO, NV 89801

ADDRESS AT WELL LOCATION NIGHTHAWK DRIVE
MVR #3, BLOCK 7, SOT 7
Subdivision Name: Meadow Valley Rancho #3 County: ELKO

2. LOCATION NW ¼ NE ¼ Sec 3 T 35N N/S R 56 E
PERMIT/WAIVER No. 035-007-007
Issued by Water Resources Parcel No.

Latitude 40.952835
Longitude 115.649174
UTM E 11T 0613692 [X] NAD 27
N 4534188 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
BROWN CLAY		2	100	98
GRAVEL W/SOME BRN CLAY		100	125	25
CLAY W/ SOME GRAVEL		125	135	10
GRAVEL	XX	135	165	30
CLAY		165	170	5
GRAVEL	XXX	170	200	30

Date started: 10-Sep, 20 07
Date completed: 11-Sep, 20 07

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13.	.188	+2	200

Perforations:
Type of perforation MACHINED MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 5 to 100 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 100 to 200 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 59 feet below land surface
Artesian Flow: NO G.P.M. P.S.I.
Water Temperature COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2335
Signed Dan R Schm (By driller performing actual drilling on site or contractor)
Date 9/18/2007

STATE ENGINEERS OFFICE
2007 NOV -5 AM 11:36
RECEIVED

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY