STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 104808
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 41346

1. OWNER ABEL GONZOLEZ
MAILING ADDRESS 161 KITTRIDGE CANYON, UNIT 9
ELKO, NV 89801

ADDRESS AT WELL LOCATION 2165 OIL WELL ROAD
KITTRIDGE CANYON, ELKO, NV 89801
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION SE ¼ NW ¼ Sec 34 T 35N N/S R 55 E
PERMIT/WAIVER No. 006-10B-032
Issued by Water Resources Parcel No.

Latitude 40.879631
Longitude 115.761920
UTM E 11T 0603812 [X] NAD 27
N 4525914 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL		0	2	2
BOWN CLAY		2	4	2
SAND & GRAVEL & CLAY MIX		4	36	32
SANDSTONE		36	55	19
SILTSTONE		55	80	25
SILTSTONE & GRAVEL MIX	81	80	140	60

Date started: 6-Jun , 20 07
Date completed: 7-Jun , 20 07

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+1	140

Perforations:
Type of perforation MACHINE MILL SLOT
Size of perforation 3/16" X 3", 6 ROW
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 5 to 50 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 50 to 140 [ ] Pumped [X] Poured
Type: 3/8" PEA GRAVEL
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 22 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed (By driller performing actual drilling on site or contractor)
Date [redacted] 6/9/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY