

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

office use only  
Log No. 104810  
Permit No.  
Basin. 021

NOTICE OF INTENT NO 57350

1. OWNER **Richard Olson**  
MAILING ADDRESS **1195 Heartpine St**  
**Reno, NV 89506**

ADDRESS AT WELL LOCATION  
Latitude N 40.40831  
Longitude W 119.83370

**2695 Surprise Valley RD**  
WGS 84

2. Location **SW 1/4 SE 1/4 3 Sec T29 N R19 E** **Washoe County**  
PERMIT NO. **071-010-18** SUBDIVISION NAME

3. WORK PERFORMED | 4. PROPOSED USE | 5. WELL TYPE  
 New Well Replace Recondition |  Domestic Irrigation Test | Cable  Rotary RVC  
 Deepen Abandon Other | Municipal/Industrial Monitor Stock | Air Other  Mud

6. LITHOLOGIC LOG

Material	Water/Strata	From	To	Thickness
Sand.		0	23	23
Hard rock.		23	72	49
Volcanic.		72	126	54
Gray clay.		126	131	5
Volcanic.		131	150	19

8. WELL CONSTRUCTION

Depth Drilled **150 feet** Depth Cased **150 feet**  
 HOLE DIAMETER (BIT SIZE)  
 From To  
**10 5/8** inches **0** feet **60** feet  
**8 3/4** inches **60** feet **150** feet  
 inches feet feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>6 5/8</b>	<b>12.94</b>	<b>188</b>	<b>+2</b>	<b>150</b>

Perforations:

Type Perforation	Factory
Size perforation	<b>3/32 x 3"</b>
From <b>90</b> feet to <b>110</b> feet	
From <b>130</b> feet to <b>150</b> feet	
From feet to feet	
From feet to feet	
From feet to feet	
From feet to feet	
From feet to feet	
Surface Seal <input checked="" type="checkbox"/> YES No	Seal Type:
Depth of Seal <b>50</b> feet	<input checked="" type="checkbox"/> Neat Cement
<input checked="" type="checkbox"/> Pumped	Cement Grout
Poured	Concrete Grout
Gravel Packed: <input checked="" type="checkbox"/> Yes No	
From <b>50</b> feet to <b>150</b> feet	

2007 JUN 27 AM 11:09  
 STATE ENGINEERING OFFICE

9. WATER LEVEL

Static water level **25** feet below land surface  
 Artesian flow **0** GPM **0** P.S.I.  
 Water Temperature **cold** Degrees F Quality

Date started **6-11 -07**  
 Date completed **6-20 -07**

7. WELL TEST DATA


TEST METHOD:	Bailer	Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (hours)	
<b>10</b>	<b>25</b>		
<b>15</b>	<b>50</b>		
<b>20</b>	<b>75</b>		
<b>30</b>	<b>125</b>		

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **McKay Drilling, Inc.**  
**2290 Pioneer Drive**  
**Reno, NV 89509**

NV Contractors No. **14170**  
 NV Driller's Lic (on site) **2121**

Signed   
 By driller performing actual drilling on site or contractor

Date **6-21 -07**

N40.408432  
 W 119.832681 NAD27