WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 104873
Permit No.
Basin 212

NOTICE OF INTENT NO. 34807

1. OWNER COUNTY OF CLARK (PARK & COMM SERV)
MAILING ADDRESS 5525 South Valley View #10
LAS VEGAS NV 89118

ADDRESS AT WELL LOCATION 1020 BROADBENT Blvd.
WHITNEY LIST. STATION LAS VEGAS NV

2. LOCATION NW ¼ SE ¼ Sec. 26 T. 21 N/S R. 62 E. CLARK County
PERMIT NO. DW-1237 Issued by Water Resources
161-26-701-001 Parcel No.
CLARK Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE Dewater.
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
3# WELL ABONMENT		GRADE		48'
14" CASING			48'	
CLAY-TAN		48'		3'
			51'	
STEEL-PLATE				
Waiver # DW-1237				
GPS 36° 05' 29N NAD 83				
115° 01' 07W				
#12 YARD-Neat cement.				
PULLED CASING				

Date started FEB 14 2008, 20
Date complated FEB 15 2008, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR-DWR RECEIVED FEB 20 2008 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
Depth Drilled 3' Feet Depth Cased 48' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12¼	Inches	GRADE	Feet	51'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"		250	GRADE	50'
14"		.250	18" STICK-up	30'

Perforations:
Type perforation FACTORY
Size perforation ¼ x 25" LONG 16 AROUND
From 30' feet to 50' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 7' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T.D.C. Drilling Water Well + Pump Service Contractor
Address 2870 WEBBLE Rd. Contractor
LAS VEGAS NV. 89123
Nevada contractor's license number issued by the State Contractor's Board 59948
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010
Signed (By driller performing actual drilling on site or contractor)
Date FEB 20 2008

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627