WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105036
Permit No. 22735
Basin 162

NOTICE OF INTENT NO. 32659

**1.** OWNER PAHRUMP UTILITIES
MAILING ADDRESS SW CORNER 160 & CAAS RD
PAHRUMP, NV

ADDRESS AT WELL LOCATION SW CORNER 160 & CAAS RD

**2.** LOCATION SW 1/4 SE 1/4 Sec. 3 T 21 S N/S R 54 E NYE County
PERMIT NO. 22735 Issued by Water Resources
47-021-21 Parcel No.
Subdivision Name

**3. WORK PERFORMED**
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other

**4. PROPOSED USE**
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

**5. WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thick-ness |
|---|---|---|---|---|
| INSTALL NEW LINER | | | | |
| INSIDE EXISTING OLD | | | | |
| CASING BECAUSE OF BAD | | | | |
| CONDITION OF OLD | | | | |
| CASING. | | | | |
| WGS84 | | | | |
| N 36 DEGREES 08.994 | | | | |
| WEST 115 DEGREES 53.751 | | | | |

DCNR/DWR
RECEIVED
MAR 0 5 2008
LAS VEGAS OFFICE

Date started 2/4/2008 , 19__
Date completed 2/8/2008 , 19__

**7. WELL TEST DATA**
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

**8. WELL CONSTRUCTION**
Depth Drilled EXISTING Feet Depth Cased 720 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | To |
|---|---|---|---|
| EXISTING | Inches | Feet | Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 16 EXISTIN | | | 0 | 720 |
| 12 | 33.38 | .250 | 0 | 300 |
| 10 | 28.04 | .250 | 300 | 702 |

**Perforations:**
Type perforation SAWCUT
Size perforation 1/8 X 3
From 300 feet to 702 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

**9. WATER LEVEL**
Static water level 19 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor
Address 1220 E MANSE RD
Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed
By driller performing actual drilling on-site or contractor
Date 2/8/2008

USE ADDITIONAL SHEETS IF NECESSARY