

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34808

1. OWNER SCP Silverado LLC ADDRESS AT WELL LOCATION 3024 Hardin Dr, Henderson NV 89074  
 MAILING ADDRESS 7914 N. Shadeland Ave Indianapolis IN 46250  
 2. LOCATION SW 1/4 SW 1/4 Sec. 24 T. 22 R. 61 E. Clark County  
 PERMIT NO. 177-24-401-008 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandoned existing well to 200 ft. Refer well log # 57479				
Pulled well pump equipment completely from the well				
Attempted to pull steel casing - perforated casing from 200 ft to 50 feet with mill knife perforator				
On 3/25/08 we pumped in 8 yards of neat cement through a tremmie pipe from the bottom of the well to 2 feet from the surface. On 3/26/08 we poured 1 yard of cement grout from 2 ft to the surface completely filling well.				
GPS 36° 00' 49" N NAD 83 115° 07' 01" W				
PLUGGING OF LOG # <u>57479</u>				

Date started 3/25/08, 20\_\_\_\_  
 Date completed 3/26/08, 2008

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

MAR 28 2008  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>				

 Perforations:  
 Type perforation Mill knife  
 Size perforation \_\_\_\_\_  
 From 200 feet to 50' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From Cut 4 times feet to \_\_\_\_\_ feet  
 From Around every feet to \_\_\_\_\_ feet  
 From 2 feet feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal \_\_\_\_\_  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 104 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name TDC Drilling Contractor  
 Address 2870 W Pebble Rd Contractor  
Las Vegas, NV 89123  
 Nevada contractor's license number issued by the State Contractor's Board 59948  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2010  
 Signed Thomson  
 By driller performing actual drilling on site or contractor  
 Date March 27 2008