STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105108
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61013

1. OWNER CHRISTIAN FUNK
MAILING ADDRESS 2457 JUNIPER LN
SE GARDNERVILLE , NV 89410

ADDRESS AT WELL LOCATION 1819 sterling ranch rd
gardnerville , nv 89410
Subdivision Name: County: Douglas

2. LOCATION ~~SW~~ ¼ ~~NE~~ ¼ Sec 1 T 12N N/S R 20 E
PERMIT/WAIVER No. SW 1220-01-002-056
Issued by Water Resources Parcel No.

Latitude 38.92657°N
Longitude 119.69034°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
LARGE GRAVELS		3	85	82
COURSE BROKEN GRANELS		82	108	26
BROWN CLAY		108	163	55
FRACTURED GRAVELS		163	189	26
SMALL CLAY SEAMS				
FRACTURED OBSIDIAN	XXX	189	240	51
GRAVELS				
N 38.926669				
W 119.689346 NAD27				

Date started: 29-Nov , 20 07
Date completed: 04-Dec , 20 07

9. WELL CONSTRUCTION
Depth Drilled 240' Feet Depth Cased 240' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
sdr 21	4.06	~~.216~~ .316	20	240

Perforations:
Type of perforation SAW CUT
Size of perforation 3 X 3/32
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout 0 to 65 ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 65 to 240 ☐ Pumped ☒ Poured
Type: WASHED PEA GRAVEL
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 93 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	49	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name
Contractor
Address
Contractor
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed
By driller performing actual drilling on site or contractor
Date 12/11/2007

2007 DEC 13 AM 11:36

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY