STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105110
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61014

1. OWNER WARREN ANDREWS
MAILING ADDRESS 1570 SHIRLEY ST
NE MINDEN , NV 89423

ADDRESS AT WELL LOCATION 1570 SHIRLEY ST
MINDEN , NV 89423
Subdivision Name: County: DOUGLAS

2. LOCATION ~~NE~~ SE ¼ ~~NW~~ ¼ Sec 34 T 14N N/S R 20 E
PERMIT/WAIVER No. SE 1420-34-710-065
Issued by Water Resources Parcel No.

Latitude 39.03059*N
Longitude 119.71704*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD WELL 8 5/8		+2	122	120
COURSE DG SANDS		122	165	43
BROWN CLAY		165	182	17
COURSE DG SANDS		182	220	38

N39.030691
W 119.716044 NAD27

Date started: 30-Nov , 20 07
Date completed: 11/30/2007 , 20 07

7. Water Level
Static water level: 85 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+	45	3 HRS

9. WELL CONSTRUCTION
Depth Drilled 220 ~~100~~ Feet Depth Cased 220 ~~100~~ Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8	inches	120 Feet	220 Feet
	inches	Feet	Feet
	inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	100	220

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3 X 3/32
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address # 20 KIT KAT DRIVE
Contractor
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 12/06/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

2007 DEC 13 AM 11:36