STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105116
Permit No.
Basin Ø66

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61267

1. OWNER Barrick Gold Exploration
MAILING ADDRESS 293 Spruce Road
Elko, NV 89801

ADDRESS AT WELL LOCATION 19 mi. NE of Golconda/ I-80 Exit 194
Hole #RMW3W
Subdivision Name: County: Humboldt

2. LOCATION NW ¼ SE ¼ Sec 33 T 38N N/S R 42 E
PERMIT/WAIVER No. NEV2005102
Issued by Water Resources Parcel No.

Latitude 41.126628
Longitude 117.245143
UTM E 479422 [x] NAD 27
N 4552630.95 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium & Clay		0	400	400

Date started: 30-Nov , 20 07
Date completed: 4-Dec , 20 07

9. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14	Inches	0	Feet	20	Feet
8 3/4	Inches	20	Feet	400	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4	Nominal	Sch. 80	+2	318

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 278 feet to 318 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 0 to 50 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 318 to 400 [ ] Pumped [x] Poured
Type: #8 Sand
Bentonite Chips: [x] Yes [ ] No 50 to 318 [ ] Pumped [x] Poured
Type: 3/8" kwik plug

7. *Water Level*
Static water level: 272 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Milky

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8	128	30 min.

STATE ENGINEER'S OFFICE
2007 DEC 12 AM 11:16
RECEIVED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc.
Contractor
Address PO Box 2748
Contractor
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M2260
Signed Reese Schoorl by [illegible]
By driller performing actual drilling on site or contractor
Date 12/4/2007

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY