

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 60377

1. OWNER Rick Ackerson ADDRESS AT WELL LOCATION 2583 FREMONT
 MAILING ADDRESS _____
 2. LOCATION NE 1/4 NW 1/4 Sec. 02 T. 12N N/S R. 20 E Douglas County
 PERMIT NO. 1320-02-001.083 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DIRT - LARGE GRAVEL</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>BROWN DENSE CLAY</u>		<u>8</u>	<u>38</u>	<u>30</u>
<u>CLAY - LARGE GRAVEL</u>		<u>38</u>	<u>92</u>	<u>54</u>
<u>LARGE GRAVEL - COBBLES</u>		<u>92</u>	<u>144</u>	<u>52</u>
<u>BROWN CLAY - ROCK</u>		<u>144</u>	<u>176</u>	<u>32</u>
<u>FRAC ROCK - GRAVEL</u>	<input checked="" type="checkbox"/>	<u>176</u>	<u>208</u>	<u>32</u>
<u>DENSE BROWN CLAY</u>		<u>208</u>	<u>220</u>	<u>12</u>
<u>N39.025910</u>				
<u>W 119.707944 NAD27</u>				
<u>39.02581° N</u>				
<u>119.70899° W NAD83</u>				

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
105/8 Inches 0 Feet 50 Feet
97/8 Inches 50 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>13</u>	<u>.188</u>	<u>±1</u>	<u>20</u>
<u>65/8</u>	<u>4</u>	<u>SDR21</u>	<u>20</u>	<u>220</u>

Perforations:
 Type perforation GRINDER CUT
 Size perforation .045" x 4"
 From _____ feet to _____ feet
 From 180 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 56 ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 56 feet to 220 feet

9. WATER LEVEL
 Static water level 166 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality CLEAR

Date started 28 NOV, 2007
 Date completed 5 DEC, 2007

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>8-10</u>	<u>18-1</u>	<u>12.0</u>
	<u>18-1</u>	<u>16.3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name BLAIN DRILLING & PUMP CO. INC.
 Address P.O. Box 1255 Carson City, NV 89702
 Nevada contractor's license number issued by the State Contractor's Board 46498
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
 Signed Jack Wilson
 By driller performing actual drilling on site or contractor
 Date 13 DEC 07