

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 105146
 Permit No. _____
 Basin 162

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32685

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

1. OWNER JEFFREY VONALST
 MAILING ADDRESS 4021 W BLANCHARD ST
PAHRUMP, NV

ADDRESS AT WELL LOCATION 4021 W BLANCHARD ST

2. LOCATION NE 1/4 NW 1/4 Sec. 26 T 20S
 PERMIT NO. 28-592-28
Issued by Water Resources Parcel No.

N/S R 52E E NYE County
VEGAS ACRES UNIT 2
Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHE		0	73	73
CALICHE	WB	73	79	6
CLAY		79	102	23
CALICHE	WB	102	106	4
CLAY		106	132	26
CALICHE	WB	132	143	11
CLAY		143	171	28
CALICHE	WB	176	200	24
WGS84				
N 36 DEGREES 11.296				
WEST 116 DEGREES 05.145				

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>200</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 1/8 X 3
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet


9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor
 Address 1220 E MANSE RD
Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed [Signature]
 By driller performing actual drilling on-site or contractor
 Date 5/2/2008

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift
 G.P.M. _____ Draw Down (Feet Below Static) _____ Time (Hours) _____



USE ADDITIONAL SHEETS IF NECESSARY