

246801
 PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33517

1. OWNER ACE LAB INC ADDRESS AT WELL LOCATION 5010 S. VALLEY VIEW
 MAILING ADDRESS 5010 S. VALLEY VIEW BLVD PARADISE
LAS VEGAS NV
 2. LOCATION NW 1/4 NW 1/4 Sec 29 T. 21 N/S R. 61 E. CLARK County
 PERMIT NO. 162-29-101-043 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ASPHALT</u>		<u>0</u>	<u>.4</u>	<u>.4</u>
<u>TYPE II</u>		<u>.4</u>	<u>1</u>	<u>.6</u>
<u>SILTY CLAY</u>		<u>1</u>	<u>10</u>	<u>9</u>
<u>SILTY CLAY w/ GRAVEL</u>		<u>10</u>	<u>18.5</u>	<u>8.5</u>
<u>WEAK SANDY CLAY</u>		<u>18.5</u>	<u>23</u>	<u>4.5</u>
<u>CLAY</u>		<u>23</u>	<u>25</u>	<u>2</u>

MAP DATUM WGS 84
 VE-2 36°05.917N 115°11.339W
 FACILITY ID # 8-000204

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cased 25 Feet
 HOLE DIAMETER (BIT SIZE)
 From 11/16 Inches To 25 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.25</u>		<u>SC40 PL</u>	<u>25</u>	<u>0</u>

Perforations:
 Type perforation MACHINE SLOT
 Size perforation 1020
 From 25 feet to 22.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 20.5 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 25 feet to 20.5 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 4/01, 2008
 Date completed 4/01, 2008

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

DCNR/DWR RECEIVED
 APR 16 2008
 LAS VEGAS OFFICE

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ETABE DRILLING SERVICES LLC Contractor
 Address 7150 PLANO ST. Contractor
LAS VEGAS NV 89119
 Nevada contractor's license number issued by the State Contractor's Board 51266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 4/14/08