

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 105155
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32682

1. OWNER **GEORGINA ERRETT** ADDRESS AT WELL LOCATION **1050 CARSON**
 MAILING ADDRESS **1050 CARSON**
PAHRUMP, NV

2. LOCATION **SW** 1/4 **NW** 1/4 Sec. **14** T **21S** N/S R **53E** E **NYE** County
 PERMIT NO. **44-721-02** **MESA OESTE ESTATES UNIT 1**
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
EXISTING 140 FT 8" STEEL WELL				
CALICHE	WB	140	149	9
CLAY		149	168	19
CALICHE	WB	168	185	17
CLAY		185	215	30
CALICHE	WB	215	220	5
CLAY		220	230	10
CALICHE	WB	230	240	10
WGS84				
N 36 DEGREES 07.635				
W 115 DEGREES 59.504				

DCNR/DWR RECEIVED
 APR 23 2008
LAS VEGAS OFFICE

Date started 4/8/2008, 19____
 Date completed 4/8/2008, 19____

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)		Time (Hours)
	G.P.M.		
<input type="checkbox"/> Baifer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)
 EXISTING 8 Inches From 0 Feet To 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXISTING 8" STEEL		.188	0	140
4.5	2.36	.248	0	240


Perforations:
 Type perforation **SAW CUT**
 Size perforation 1/8 X 3

From 140 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal **EXISTING**
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout

Gravel Packed: Yes No
 From 140 feet to 200 feet

9. WATER LEVEL
 Static water level 125 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.**
Contractor
 Address **1220 E MANSE RD**
Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1428**
 Signed 
By driller performing actual drilling on-site or contractor
 Date **4/11/2008**