STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105160
Permit No.
Basin 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61260

1. OWNER Newmont Mining Corp.
MAILING ADDRESS PO Box 669
Carlin, NV 89822

ADDRESS AT WELL LOCATION TS Power Plant
TSMW6
Subdivision Name: County: Eureka

2. LOCATION SE ¼ SW ¼ Sec 2 T 33N N/S R 48 E
PERMIT/WAIVER No. M/O-1473
Issued by Water Resources Parcel No.

Latitude 40.756866
Longitude 116.531477
UTM E 539549.09 [x] NAD 27
N 4511661.55 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium	32	0	60	60

Date started: 17-Nov, 20 07
Date completed: 17-Nov, 20 07

9. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 58 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	10	Feet
6 1/4	Inches	10	Feet	60	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		3/16	0	10
2		Sch 80	0	58

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From 38 feet to 58 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[ ] Neat Cement 0 to 16 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [x] Yes [ ] No 36 to 60 [ ] Pumped [x] Poured
Type: #8 Sand
Bentonite Chips: [x] Yes [ ] No 16 to 36 [ ] Pumped [x] Poured
Type: 3/8" hole plug

7. Water Level
Static water level: 32 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	0	30 min.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2347
Signed Abe Schaefer by [illegible] (By driller performing actual drilling on site or contractor)
Date 11/20/2007

STATE ENGINEER'S OFFICE
2007 NOV 29 AM 10: 32

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY