WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 105165
Permit No.
Basin 070

NOTICE OF INTENT NO. 51364

1. OWNER Gale Griggs
MAILING ADDRESS P.O. Box 57
Orvada NV 89425

ADDRESS AT WELL LOCATION 4630 Teal Lane
Winnemucca, NV

2. LOCATION SE ¼ SE ¼ Sec. 2 T. 35 N/S R. 37 E. Humboldt County
PERMIT NO. Issued by Water Resources | 13-037-04 Parcel No. | JB Estates NAD27 Subdivision Name | UTM 434635E 4531448.

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sand | | 0 | 5 | |
| Clay | | 5 | 25 | |
| Sand & Clay | | 25 | 45 | |
| heavy Sand | | 45 | 65 | |
| gravel | X | 65 | 85 | |
| gravel | X | 85 | 105 | |
| Sand & gravel | X | 105 | 125 | |
| Sand & gravel | X | 125 | 145 | |
| Sand & gravel | X | 145 | 165 | |
| Sand & gravel | X | 165 | 185 | |
| Sand & gravel | X | 185 | 205 | |
| Sand & gravel | X | 205 | 225 | |
| Course gravel | X | 225 | 230 | |

N40.933452
W 117.776411 NAD27

Date started 11-10, 2006
Date complated 11-15, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 10 3/4 | 0 | 230 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | 3/16 | +2 | 230 |
| | | | | |
| | | | | |

Perforations:
Type perforation Punched
Size perforation 3/16" x 1½"
From 200 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 230 feet

9. WATER LEVEL
Static water level 58 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling (Contractor)
Address 3040 Callahan St (Contractor)
Winnemucca NV 89445
Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2208
Signed Owen Brinkerhoff (By driller performing actual drilling on site of contractor)
Date 11/20/06

RECEIVED 2006 DEC 18 AM 11:34 STATE ENGINEERS OFFICE

RECEIVED 2007 NOV 29 AM 10:35 STATE ENGINEERS OFFICE

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627