

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61458

1. OWNER El Paso Corporation ADDRESS AT WELL LOCATION 1200 Americam Flatf
Spring, Co 80903 Virginia City NV

2. LOCATION NE 1/4 NE 1/4 Sec 6 T 16 N/S R 21 E Lyon County

PERMIT NO. NE Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
A 1 inch tremie pipe was set to 98 ft and neat cement was pumped to surface.				
casing was pulled and brok at suface.				
the well was top off with neat cement to surface.				
<u>N 39.287344</u>				
<u>W 119.661232 NAD27</u>				
<u>HM-9</u>				

8. WELL CONSTRUCTION
 Depth Drilled 99.9 Feet Depth Cased 99.9 Feet

HOLE DIAMETER (BIT SIZE)
 From To
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.5</u>	<u>PVC</u>			

Perforations:
 Type perforation _____
 Size perforation _____
 From 99.9 feet to 89 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 99.9 feet to 50 feet

9. WATER LEVEL
 Static water level 97.09 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 50 °F Quality poor

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Knoblock & Sons Pump and Supply
 Contractor
 Address 5425 Spanish Moss Sparks NV 89436
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 49162
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller AB-2213

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 11/15/2007

Date started 10/19/ 2007
 Date completed 10/19/ 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			