STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 103216
Permit No.
Basin 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61274

1. OWNER Newmont Mining Corp.
MAILING ADDRESS PO Box 669
NE Carlin, NV 89822

ADDRESS AT WELL LOCATION North Area
Hole #NA3BD
Subdivision Name: County: Eureka

2. LOCATION ~~NW~~ ¼ SW ¼ Sec 33 T 36N N/S R 50 E
PERMIT/WAIVER No. order # 1038
Issued by Water Resources Parcel No.

Latitude 40.952956 UTM E 4533539 [x] NAD 27
Longitude 116.330104 N 0556381 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [x] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	155	155
Sand & Brown Clay		155	415	260
Brown Clay		415	465	50
Volcanics		465	520	55
Tan Rock		520	700	180
Grayish Black Rock		700	760	60
Tan Clay		760	765	5
Grayish Black Rock		765	840	75

Date started: 9-Jan , 20 08
Date completed: 17-Jan , 20 08

9. *WELL CONSTRUCTION*
Depth Drilled 840 Feet Depth Cased 818 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
15	Inches	0	Feet	40	Feet
9 7/8	Inches	40	Feet	540	Feet
6	Inches	540	Feet	840	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 3/8	N/A	Sch 40	+2	818
10	N/A	156 Wall	+3	37

Perforations:
Type of perforation Vertical Slot
Size of perforation 1/8"

From	Blank 818	feet to	798	feet
From	Screen 798	feet to	778	feet
From	Blank 778	feet to	+2	feet
From		feet to		feet
From		feet to		feet

Annular Seal: [x] Yes [ ] No

[x] Neat Cement	0 to 50	[ ] Pumped	[x] Poured
[ ] Cement Grout	to	[ ] Pumped	[ ] Poured
[ ] Concrete Grout	to	[ ] Pumped	[ ] Poured
[ ] ≥30% Bentonite Grout	to	[ ] Pumped	[ ] Poured

Gravel Pack: [x] Yes [ ] No 820 to 770 [ ] Pumped [x] Poured
Type: 1/4" Gravel
Bentonite Chips: [x] Yes [ ] No 770 to 50 [ ] Pumped [x] Poured
Type: 3/8" Chips

7. *Water Level*
Static water level: 100 feet below land surface
Artesian Flow: No G.P.M. 1 P.S.I.
Water Temperature: N/A °F
Quality: Clean

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [x] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
840	70	N/A	15 min
Before			
constructing			
well			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1942
Signed William Riley by [signature] (By driller performing actual drilling on site or contractor)
Date 1/17/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY