STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 105224
Permit No.
Basin 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61274

1. OWNER Barrick Gold
MAILING ADDRESS PO Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION North Area
Hole #NAB-00003S
Subdivision Name: County: Eureka

2. LOCATION ~~NW~~ NE ¼ SW ¼ Sec 33 T 36N N/S R 50 E
PERMIT/WAIVER No. order # 1038
Issued by Water Resources Parcel No.

Latitude N40.952956 UTM E 4533539 [x] NAD 27
Longitude W116.330104 N 0556381 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [x] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [x] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	155	155
Sand & Brown Clay		155	400	245

Date started: 10-Dec , 20 07
Date completed: 15-Dec , 20 07

9. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	19	Feet
6	Inches	19	Feet	400	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
1 1/4		Sch 80	+1	380

Perforations:
Type of perforation Slotted
Size of perforation 0.02
From Blank 380 feet to 370 feet
From Screen 370 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No
[x] Neat Cement 0 to 54 [ ] Pumped [x] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [x] Yes [ ] No 400 to 345 [ ] Pumped [x] Poured
Type: #8 Sand
Bentonite Chips: [x] Yes [ ] No 345 to 54 [ ] Pumped [x] Poured
Type: 3/8" Bentonite Chips

7. Water Level
Static water level: 212 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		.25

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eklund Drilling Company, Inc. (Contractor)
Address PO Box 2748 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 0030823
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1776
Signed Arthur Steelman by mb (By driller performing actual drilling on site or contractor)
Date 2/14/2008

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY