

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. \_\_\_\_\_  
 Permit No. \_\_\_\_\_  
 Basin Ø72

NOTICE OF INTENT NO. 60416

1. OWNER Golden Predator ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS PO Box 325 275 1768 E  
Imlay NV 89418 15317016 N  
 2. LOCATION SW 1/4 SE 1/4 Sec. 35 T. 34 N. R. 34 E Pershing County  
 PERMIT NO. MW 1455 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

| Material                  | Water Strata | From | To  | Thickness |
|---------------------------|--------------|------|-----|-----------|
| Alluvium                  |              | 0    | 17  |           |
| Hornfels w<br>Glaucophane |              | 17   | 40  |           |
| Hornfels                  |              | 40   | 600 |           |
| N40.773685                |              |      |     |           |
| W 118.123440 NAD27        |              |      |     |           |

8. WELL CONSTRUCTION  
 Depth Drilled 600 Feet Depth Cased 600 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 8.5 Inches To 6.90 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE  

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>4"</u>          |                     | <u>sch 80</u>           | <u>0</u>    | <u>440</u> |

 Perforations:  
 Type perforation 510fs  
 Size perforation Ø20  
 From 440 feet to 600 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 438  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 438 feet to 600 feet  
 9. WATER LEVEL  
 Static water level 352.3 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7-23, 2007  
 Date completed 7-27, 2007

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours)            |
|--------------|--------|-------------------------------|-------------------------|
| <u>NA</u>    |        | <u>36:11:11</u>               | <u>2007 DEC 8 11:36</u> |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WDC Contractor  
 Address PO Box 141 Contractor  
Zamora CA 95698  
 Nevada contractor's license number 12852  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2111  
 Signed Jay Whitley  
 By driller performing actual drilling on site or contractor  
 Date 11-14-07