

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 100259
 Permit No. Ø90
 Basin Ø90

NOTICE OF INTENT NO. 57864

1. OWNER GEORGE SCHMIDT ADDRESS AT WELL LOCATION 1186 HWY 50
 MAILING ADDRESS P.O. BOX 1219 ZEPHYR COVE. NV. 89449
 2. LOCATION NW ¼ NW ¼ Sec. 15 T 13 N/S R 18 E DOUGLAS County
 PERMIT NO. 71348 Issued by Water Resources Parcel No. 1318-15-101-003 Subdivision Name 38 59 MIN 39.8 NORTH / 119° 57' M 12.07 W.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Sonic

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DUE TO CEMENT SEAL 0 TO 30' CASING COULD NOT BE PULLED.				
INTERIOR COLUMN OF CASING FILLED WITH NEAT CEMENT FILLED AGAIN TO 5' BELOW GROUND SURFACE THEN TOP 5' REMOVED.				
N 38.994230				
W 119.952356 NAD27				

8. WELL CONSTRUCTION
 Depth Drilled 65 Feet Depth Cased 6.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/4 Inches To 6.5 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>18.79</u>	<u>.280</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation WIRE WRAP
 Size perforation _____
 From 3.5 feet to 6.5 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 30 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 30 feet to 6.5 feet

9. WATER LEVEL
 Static water level 11 feet below land surface
 Artesian flow N/D G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PROSONIC (BOBRT LOOSEYER) Contractor
 Address 12464 MCCANN DR SPRING CA. 90670 Contractor SMITH FIE

Nevada contractor's license number issued by the State Contractor's Board 0061765
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2393
 Signed W.R. Schmidt
 By driller performing actual drilling on site or contractor
 Date Nov. 19, 2007

7. WELL TEST DATA

TEST METHOD:	G.P.M.		
	Draw Down (Feet Below Static)	Time (Hours)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>54:6 MIN</u>	<u>20</u>	<u>2007 NOV 20 AM 9:45</u>